

CERTIFIED/LISTED PRODUCTS

NSF/ANSI STANDARD 385 Disinfection Mechanics

Sect. 6 – Chlorine Disinfection Devices:

Norweco, Inc.
 220 Republic Street
 Norwalk, OH 44857-1156
 United States
 419-668-4471
www.norweco.com

Facility: Norwalk, OH

Model	Rated Capacity (GPD)	Classification	Listing Date
Bio-Dynamic LF Series Tablet Feeders *		Chlorine Disinfection Device	
Model LF 500	200 – 1500		10 Feb 2021
Model LF 1000	200 – 1500		18 Nov 2020
Model LF 1500 **	200 – 1500		10 Feb 2021
Model LF 2000 **	200 – 1500		10 Feb 2021
Model LF 3000 **	200 – 1500		10 Feb 2021
Model LF 4600 **	200 – 1500		10 Feb 2021
Model LF 4800 **	200 – 1500		10 Feb 2021
Bio-Dynamic Series 2000 Tablet Feeders *		Chlorine Disinfection Device	
Models XT 2000 / XT 2000-S **	200 – 1500		28 May 2021
Models IT 2000 / IT 2000-S **	200 – 1500		28 May 2021
Model ITR 2000-S**	200 – 1500		28 May 2021
Bio-Dynamic Series 4000 Tablet Feeders *		Chlorine Disinfection Device	
Models XT 4000 / XT 4000-S **	200 – 1500		28 May 2021
Models IT 4000 / IT 4000-S **	200 – 1500		28 May 2021
Model ITR 4000-S **	200 – 1500		28 May 2021
Bio-Kinetic System *	200 – 600	Chlorine Disinfection Device	19 Apr 2024

*Certified with the use of Bio-Sanitizer or Blue Crystal Disinfecting Tablets.

**Although certain model disinfection devices may be capable of disinfecting flows greater than 1500 GPD, the scope of the Standard does not apply to treatment capacities outside the range of 200 – 1500 GPD.



High Standards • Integrity • Technical Expertise



Sect. 7 - Ultraviolet Disinfection Devices:

Norweco, Inc.
 220 Republic Street
 Norwalk, OH 44857-1156
 United States
 419-668-4471
www.norweco.com

Facility: Norwalk, OH

Model	Rated Capacity (GPD)	Classification	Listing Date
AT 1500 UV Disinfection System	500	Gravity Flow	14 Oct 2022

Sect. 8 - Ozone Disinfection Devices:

No Listed Products for this Category